
10" Ø PRECAST CONCRETE

- GROUNDING ELECTRODE

SERVICE PULL BOX. INSCRIBE "GROUND" ON COVER

TO ACCOMPANY PLANS DATED \_





# GROUNDING BUSHING GROUND CLAMP BY MIN GROUND CLAMP BY MIN GROUND FACE OF WOOD POLE OR FACE OF CONCRETE FOUNDATION FOR STEEL POLE TYPE A See Note 1 See Note 2

## SERVICE GROUNDING

### LEGEND:

- 1 METER SOCKET.
- 2 SERVICE ENCLOSURE WITH A MINIMUM 60 A RATED MAIN CIRCUIT BREAKER, UNLESS OTHERWISE SHOWN.
- 3 A. UTILITY OWNED POLE. THE SERVICE UTILITY WILL FURNISH AND INSTALL REQUIRED SERVICE RISER, PEU WITH CONDUCTORS AND OTHER EQUIPMENT AS NEEDED.
  - B. STATE OWNED POLE, THE CONTRACTOR SHALL FURNISH AND INSTALL REQUIRED SERVICE RISER AND EQUIPMENT.
- 2"C, SERVICE CONDUIT MUST HAVE A GROUNDED TYPE BUSHING INSTALLED AT UPPER END OF THE METALLIC POLE RISER CONDUIT. A GROUNDING COMDUITOR MUST BE ATTACHED TO THE BUSHING, CARRIED THROUGH THE CONDUIT RUN AND ATTACHED TO THE SERVICE COUMPMENT ENCLOSURE'S GROUNDING ELECTRODE.
- CONDUIT, LENGTH AND SIZE AS REQUIRED.
- 6 1/2"C, 1#6. SEE SERVICE GROUNDING.
- 7 FLASHING BEACON CONTROL ASSEMBLY.
- 8 SERVICE PULL BOX, No. 5 UNLESS OTHERWISE NOTED, FURNISHED AND INSTALLED BY THE CONTRACTOR. SERVICE UTILITY SHALL DETERMINE THE EXACT LOCATION.

### NOTES:

- Ground clamp and required fittings must be accessible. Conduit must extend to protect grounding electrode conductor from mechanical damage.
- 2. Use where service utility requires 18" clearance between grounding electrode and the pole or service equipment enclosure. Installation shown is for sidewalk or paved areas. In unpaved areas, omit special service pull box and locate ground clamp above ground or locate ground clamp in nearest pull box.

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION

# ELECTRICAL SYSTEMS (SERVICE EQUIPMENT)

NO SCALE

RSP ES-2A DATED OCTOBER 19, 2018 SUPERSEDES STANDARD PLAN ES-2A DATED MAY 31, 2018 - PAGE 478 OF THE STANDARD PLANS BOOK DATED 2018.

REVISED STANDARD PLAN RSP ES-2A

2018

ᇛ

VISE

O

STANDARD

PLAN

RSP

m

ဖ

N

Š